

C € 0085



CERT

EU type examination certificate

EU-Baumusterprüfbescheinigung

CE-0085CS0173

Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Ferrolì S.p.A. Via Ritonda 78A, I-37047 San Bonifacio (VR)
Distributor <i>Vertreiber</i>	Ferrolì S.p.A. Via Ritonda 78A, I-37047 San Bonifacio (VR)
Product Category <i>Produktart</i>	Boilers: Boiler without burner (3117)
Product Description <i>Produktbezeichnung</i>	boiler for forced draught burners
Model <i>Modell</i>	TP3 COND...
Countries of Destination <i>Bestimmungsländer</i>	European Union, CH, IS, NO, TR
Test Reports <i>Prüfberichte</i>	supplement test: K 2055 2018 B9 from 26.10.2020 (TRG) supplement test: K 2055 2018 Z8 from 26.10.2020 (TRG) supplement test: K 2055 2018 E7 from 26.10.2020 (TRG)
Test Basis <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 303-1 (01.11.2017) DIN EN 303-3 (01.10.2004) DIN EN 303-3/Ber (01.07.2007)
Date of Expiry / File No. <i>Ablaufdatum / AZ</i>	04.07.2028 / 18-0512-GEA

70226-04-A-DE

19.11.2020 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EU Regulation EU/2016/426.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EU-Verordnung EU/2016/426.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Elektrical Data 230 V AC, 50 Hz
Elektrische Daten

Installation Codes <i>Installationsarten</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
B23	CH, EU, IS, NO, TR	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
TP3 COND 65	nominal heat output: 18,0...59,5 kW heat input (Hi): 18,4...61,3 kW	
TP3 COND 100	nominal heat output: 27,7...91,5 kW heat input (Hi): 28,3...94,3 kW	
TP3 COND 150	nominal heat output: 41,6...137,3 kW heat input (Hi): 42,5...141,5 kW	
TP3 COND 230	nominal heat output: 63,8...210,5 kW heat input (Hi): 65,1...217,0 kW	
TP3 COND 370	nominal heat output: 102,6...338,6 kW heat input (Hi): 104,7...349,1 kW	
TP3 COND 500	nominal heat output: 138,7...457,5 kW heat input (Hi): 141,5...471,7 kW	
TP3 COND 650	nominal heat output: 180,3...594,8 kW heat input (Hi): 184,0...613,2 kW	
TP3 COND 820	nominal heat output: 489,0...734,0 kW heat input (Hi): 498,0...749,0 kW	
TP3 COND 1000	nominal heat output: 595,0...916,0 kW heat input (Hi): 608,0...935,0 kW	

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

The appliance categories and the gas supply pressures are according to the gas burner in use.